

Grand Tower Environmental Daily Readings

	Unit 3 Condenser Discharge (°F)	Unit 4 Condenser Discharge (°F)	Ash Pond Flow (GPM)	Daily Inspection of Outfalls Discharge & Verify No Settleable Solids, Floating Debris, Visible Oil, Grease, Scum, or Sludge Solids present. ✓ if OK × if Not OK			
				Outfall 001 (condenser & B01 disch at river)	Outfall 002 (Ash Pond)	Outfall A03 (Sewage Plant)	Outfall 003 (Stormwater Disch to River)
5/1/2018			0	✓	✓	122345	✓
5/2/2018	73	62	0	✓	✓	123015	✓
5/3/2018	62	62	0	✓	✓	123679	✓
5/4/2018	75	64	0	✓	✓	126,371	✓
5/5/2018	65	65	0	✓	✓	129063	✓
5/6/2018	65	65	0	✓	✓	1309376	✓
5/7/2018	65	65	0	✓	✓	1333	✓
5/8/2018	67	67	0	✓	✓	1340	✓
5/9/2018	80	90	0	✓	✓	1343	✓
5/10/2018	68 72	90	0	✓	✓	1359	✓
5/11/2018	88	90	0	✓	✓	1362	✓
5/12/2018	84	70	0	✓	✓	1365	✓
5/13/2018	72	90	0	✓	✓	1367	✓
5/14/2018	73	90	0	✓	✓	1376	✓
5/15/2018	73	93	0	✓	✓	1381	✓
5/16/2018	73	90	0	✓	✓	1395	✓
5/17/2018	72	90	0	✓	✓	1403	✓
5/18/2018	72	73	0	✓	✓	1425	✓
5/19/2018	72	90	0	✓	✓	1464	✓
5/20/2018	83	88	0	✓	✓	1474	✓
5/21/2018	84	88	0	✓	✓	1522	✓
5/22/2018	72	82	0	✓	✓	1526	✓
5/23/2018	72	75	0	✓	✓	1551	✓
5/24/2018	83	75	0	✓	✓	1578	✓
5/25/2018	80	80	0	✓	✓	1583	✓
5/26/2018	80	74	0	✓	✓	1602 ¹⁵⁹²	✓
5/27/2018	80	75	0	✓	✓	1602	✓
5/28/2018	77	85	0	✓	✓	1605	✓
5/29/2018	85	95	0	✓	✓	1610	✓
5/30/2018	88	96	0	✓	✓	1636	✓
5/31/2018	90	80	0	✓	✓	1687	✓

Return to Kevin's Mailbox at the end of each Month. To print off a new log sheet go to "G:\REGULATORY\ENVIRONMENTAL\Ops Daily Env Log Worksheet" folder, open the 'Ops Daily Env Log 20170201.xls' file, select the tab for the month you want, & print.