

Grand Tower Environmental Daily Readings

	Unit 3 Condenser Discharge (°F)	Unit 4 Condenser Discharge (°F)	Ash Pond Flow (GPM)	Daily Inspection of Outfalls Discharge & Verify No Settleable Solids, Floating Debris, Visible Oil, Grease, Scum, or Sludge Solids present. ✓ if OK ✗ if Not OK			
				Outfall 001 (condenser & B01 disch at river)	Outfall 002 (Ash Pond)	Outfall A03 (Sewage Plant)	Outfall 003 (Stormwater Disch to River)
6/1/2018	90	105	0	✓	✓	16909	✓
6/2/2018	80	80	0	✓	✓	1701	✓
6/3/2018	79	77	0	✓	✓	1707	✓
6/4/2018	79	79	0	✓	✓	1714	✓
6/5/2018	77	77	0	✓	✓	1722	✓
6/6/2018	79	79	0	✓	✓	1725	✓
6/7/2018	94	98	0	✓	✓	1727	✓
6/8/2018	81	100	0	✓	✓	1728	✓
6/9/2018	82	92	0	✓	✓	1729	✓
6/10/2018	81	80	0	✓	✓	1731	✓
6/11/2018	82	100	0	✓	✓	1735	✓
6/12/2018	82	100	0	✓	✓	1764	✓
6/13/2018	82	102	0	✓	✓	1802	✓
6/14/2018	82	85	0	✓	✓	1811	✓
6/15/2018	84	100	0	✓	✓	1820	✓
6/16/2018	84	100	0	✓	✓	1822	✓
6/17/2018	98	101	0	✓	✓	1823	✓
6/18/2018	93 (Am)	101	0	✓	✓	1823	✓
6/19/2018	90	100	0	✓	✓	1829	✓
6/20/2018	90	90	0	✓	✓	1833	✓
6/21/2018	86	86	0	✓	✓	1840	✓
6/22/2018	83	83	0	✓	✓	1850	✓
6/23/2018	82	82	0	✓	✓	1860	✓
6/24/2018	82	82	0	✓	✓	1866	✓
6/25/2018	82	82	0	✓	✓	1871	✓
6/26/2018	82	82	0	✓	✓	1880	✓
6/27/2018	93	100	0	✓	✓	1924	✓
6/28/2018	91	100	0	✓	✓	1927	✓
6/29/2018	92	100	0	✓	✓	1927	✓
6/30/2018	93	100	0	✓	✓	1927	✓

Return to Kevin's Mailbox at the end of each Month. To print off a new log sheet go to "G:\REGULATORY\ENVIRONMENTAL\Ops Daily Env Log Worksheet" folder, open the 'Ops Daily Env Log 20170201.xls' file, select the tab for the month you want, & print.