

Grand Tower Environmental Daily Readings

Daily Inspection of Outfalls Discharge & Verify No Settleable Solids, Floating Debris, Visible Oil, Grease, Scum, or Sludge Solids present.
 ✓ if OK × if Not OK

	Unit 3 Condenser Discharge (°F)	Unit 4 Condenser Discharge (°F)	Ash Pond Flow (GPM)	Outfall 001 (condenser & B01 disch at river)	Outfall 002 (Ash Pond)	Outfall A03 (Sewage Plant)	Outfall 003 (Stormwater Disch to River)
7/1/2018	91	100				1927	
7/2/2018	82	98				1936	
7/3/2018	86	102				1944	
7/4/2018	82	84				1951	
7/5/2018	93	102				1956	
7/6/2018	84	85				1958	
7/7/2018	88	89					
7/8/2018	92	93				195975	
7/9/2018	96	102					
7/10/2018	94	85					
7/11/2018	85	85					
7/12/2018	97	85					
7/13/2018	85	85				196989	
7/14/2018	97	85				197056	
7/15/2018	95	106				197063	
7/16/2018	97	110				197859	
7/17/2018	96	87				.3	
7/18/2018	86	110				1970	
7/19/2018	85	85				197157	
7/20/2018	85	87				197157	
7/21/2018	84	84				o/s	
7/22/2018	84	84				o/s	
7/23/2018	93	95				o/s	
7/24/2018	97	105	DRY	OK	OK	o/s	OK
7/25/2018	84	102				o/s	
7/26/2018	84	84				o/s	
7/27/2018	82	83				o/s	
7/28/2018	82	83				o/s	
7/29/2018	82	83				o/s	
7/30/2018	82	92				o/s	
7/31/2018	80	90				o/s	

Return to Kevin's Mailbox at the end of each Month. To print off a new log sheet go to "G:\REGULATORY\ENVIRONMENTAL\Ops Daily Env Log Worksheet" folder, open the 'Ops Daily Env Log 20170201.xls' file, select the tab for the month you want, & print.