

## Grand Tower Environmental Daily Readings

	Unit 3 Condenser Discharge (°F)	Unit 4 Condenser Discharge (°F)	Ash Pond Flow (GPM)	Daily Inspection of Outfalls Discharge & Verify No Settleable Solids, Floating Debris, Visible Oil, Grease, Scum, or Sludge Solids present. ✓ if OK    × if Not OK			
				Outfall 001 (condenser & B01 disch at river)	Outfall 002 (Ash Pond)	Outfall A03 (Sewage Plant)	Outfall 003 (Stormwater Disch to River)
8/1/2018	80	99	0	✓	✓	o/s	✓
8/2/2018	78	80	0	✓	✓	o/s	✓
8/3/2018	80	102	0	✓	✓	o/s	✓
8/4/2018	82	105	0	✓	✓		✓
8/5/2018	97	105	0	✓	✓		✓
8/6/2018	95	105	0	✓	✓		✓
8/7/2018	84	105	0	✓	✓		✓
8/8/2018	88	85	0	✓	✓		✓
8/9/2018	85	95	0	✓	✓		✓
8/10/2018	94	108	0	✓	✓		✓
8/11/2018	94	108	0	✓	✓		✓
8/12/2018	95	85	0	✓	✓		✓
8/13/2018	94	85	0	✓	✓		✓
8/14/2018	95	88	0	✓	✓	o/s	✓
8/15/2018	95	89	0	✓	✓	o/s	✓
8/16/2018	96	98	0	✓	✓	o/s	✓
8/17/2018	94	98	0	✓	✓	o/s	✓
8/18/2018	93	100	0	✓	✓	o/s	✓
8/19/2018	84	84	0	✓	✓	o/s	✓
8/20/2018	84	83	0	✓	✓	o/s	✓
8/21/2018	83	83	0	✓	✓	o/s	✓
8/22/2018	82	82	0	✓	✓	o/s	✓
8/23/2018	80	80	0	✓	✓	o/c	✓
8/24/2018	80	80	0	✓	✓	o/c	✓
8/25/2018	80	80	0	✓	✓	o/c	✓
8/26/2018	80	80	0	✓	✓	o/c	✓
8/27/2018	92	104	0	✓	✓	o/s	✓
8/28/2018	82	82	0	✓	✓	o/s	✓
8/29/2018	82	82	0	✓	✓	o/s	✓
8/30/2018	82	82	0	✓	✓	o/s	✓
8/31/2018	80	80	0	✓	✓	o/s	✓

Return to Kevin's Mailbox at the end of each Month. To print off a new log sheet go to "G:\REGULATORY\ENVIRONMENTAL\Ops Daily Env Log Worksheet" folder, open the 'Ops Daily Env Log 20170201.xls' file, select the tab for the month you want, & print.