

Grand Tower Environmental Daily Readings

	Unit 3 Condenser Discharge (°F)	Unit 4 Condenser Discharge (°F)	Ash Pond Flow (GPM)	Daily Inspection of Outfalls Discharge & Verify No Settleable Solids, Floating Debris, Visible Oil, Grease, Scum, or Sludge Solids present. ✓ if OK ✗ if Not OK			
				Outfall 001 (condenser & B01 disch at river)	Outfall 002 (Ash Pond)	Outfall A03 (Sewage Plant)	Outfall 003 (Stormwater Disch to River)
10/1/2018	70	80					
10/2/2018	80	90					
10/3/2018	70	90					
10/4/2018	69	85	—	✓	✓	o/s	✓
10/5/2018	69	89	✓	✓	✓	o/s	✓
10/6/2018	78	88	✓	✓	✓	o/s	✓
10/7/2018	68	94	✓	✓	✓	..	✓
10/8/2018	68	94	—	✓	—	..	—
10/9/2018	67	95	✓	✓	✓	..	—
10/10/2018	67	95	✓	✓	—	..	—
10/11/2018	65	65	✓	✓	✓	..	—
10/12/2018	64	64	—	—	—	..	—
10/13/2018	64	64	—	—	—	..	—
10/14/2018	63	62	—	—	—	..	—
10/15/2018	60	80	—	—	✓	..	✓
10/16/2018	60	75	—	—	—	..	✓
10/17/2018	58	58	✓	✓	✓	..	—
10/18/2018	57	57	—	—	✓	..	—
10/19/2018	56	56	✓	✓	✓	o/s	✓
10/20/2018	55	55	✓	—	✓	✓	—
10/21/2018	55	55	✓	✓	✓	o/s	✓
10/22/2018	55	68	✓	✓	✓	o/s	—
10/23/2018	54	66	✓	✓	✓	o/s	✓
10/24/2018	53	66	✓	✓	✓	o/s	✓
10/25/2018	53	66	✓	✓	✓	o/s	✓
10/26/2018	54	66	✓	✓	✓	o/s	✓
10/27/2018	66 66	52	✓	✓	✓	o/s	✓
10/28/2018	55 55	50	—	✓	✓	..	—
10/29/2018	50	50	✓	✓	✓	..	✓
10/30/2018	52	52	—	✓	—	..	✓
10/31/2018	52	52	✓	✓	✓	o/s	✓

Return to Kevin's Mailbox at the end of each Month. To print off a new log sheet go to "G:\REGULATORY\ENVIRONMENTAL\Ops Daily Env Log Worksheet" folder, open the 'Ops Daily Env Log 20170201.xls' file, select the tab for the month you want, & print.