

Grand Tower Environmental Daily Readings

	Unit 3 Condenser Discharge (°F)	Unit 4 Condenser Discharge (°F)	Outfall 002 Ash Pond Flow (GPM)	Outfall A03 Sewage Plant Flow (GAL)	Daily Inspection of Outfalls Discharge & Verify No Settleable Solids, Floating Debris, Visible Oil, Grease, Scum, or Sludge Solids present. ✓ if OK × if Not OK			
					Outfall 001 (condenser & B01 disch at river)	Outfall 002 (Ash Pond)	Outfall A03 (Sewage Plant)	Outfall 003 (Stormwater Disch to River)
11/1/2017	60	56	0	30921	✓	✓	✓	✓
11/2/2017	61	57	0	33342	✓	✓	✓	✓
11/3/2017	61	58	0	34522	✓	✓	✓	✓
11/4/2017	60	58	0	37618	✓	✓	✓	✓
11/5/2017	65	63	0	40012	✓	✓	✓	✓
11/6/2017	66	62	0	41818	✓	✓	✓	✓
11/7/2017	65	62	0	44984	✓	✓	✓	✓
11/8/2017	63	60	0	45963	✓	✓	✓	✓
11/9/2017	62	59	0	48310	✓	✓	✓	✓
11/10/2017	62	57	0	49416	✓	✓	✓	✓
11/11/2017	59	56	0	50471	✓	✓	✓	✓
11/12/2017	57	55	0	51166	✓	✓	✓	✓
11/13/2017	59	55	0	51859	✓	✓	✓	✓
11/14/2017	59	55	0	52618	✓	✓	✓	✓
11/15/2017	59	55	0	53686	✓	✓	✓	✓
11/16/2017	56	53	0	54123	✓	✓	✓	✓
11/17/2017	49	46	0	55918	✓	✓	✓	✓
11/18/2017	45	46	0	57114	✓	✓	✓	✓
11/19/2017	42	44	0	58571	✓	✓	✓	✓
11/20/2017	43	45	0	59198	✓	✓	✓	✓
11/21/2017	45	46	0	60004	✓	✓	✓	✓
11/22/2017	44	46	0	60509	✓	✓	✓	✓
11/23/2017	43	43	0	60854	✓	✓	✓	✓
11/24/2017	42	45	0	61036	✓	✓	✓	✓
11/25/2017	43	44	0	61222	✓	✓	✓	✓
11/26/2017	42	44	0	61401	✓	✓	✓	✓
11/27/2017	42	43	0	61676	✓	✓	✓	✓
11/28/2017	43	43	0	61898	✓	✓	✓	✓
11/29/2017	42	42	0	62011	✓	✓	✓	✓
11/30/2017	43	44	0	62341	✓	✓	✓	✓

Return to Kevin's Mailbox at the end of each Month. To print off a new log sheet go to "G:\REGULATORY\ENVIRONMENTAL\Ops Daily Env Log Worksheet" folder, open the 'Ops Daily Env Log 20170201.xls' file, select the tab for the month you want, & print.